

Examples of Lead Leaching and Lead Content Compliant Drinking Fountains and Bubblers

Brand	Description	Model	Approximate Cost	Compliance Specification – Performance Data Sheet Info
Central Brass	Bubbler Head with Flange & Shank	0360, 0361, 0362	\$70–75	IAPMO R&T to NSF/ANSI 61 ASME A112.18.1M
Central Brass	Drinking Faucet	0364-L, 0364-LV	\$135–140	ASME A112.18.1M Certified by IAPMO R&T to NSF/ANSI 61
Chicago Faucets	Drinking Fountain Bubbler	748-665ABCP	\$270–400	ASME A112.18.1/CSA B125.1 NSF/ANSI 372 Low Lead Content NSF/ANSI 61, Section 9
Homewerks Worldwide	Single Handle Water Bubbler—1/2" FPT	3310-150-CH-B-Z	\$30–40	ASME A112.18.1/CSA B125 ASME A112. 18.1M and is ANSI/NSF 61/Section 9 Certified
Elkay	Wall Mount Water Coolers	EZ4, EZ8, EZS4, EZS8, EZSD, and EZD	\$800–900	WQA-certified as lead-free compliant NSF/ANSI 61-ANNEX G, AB 1953 NO LEAD DESIGN
Halsey Taylor	Bi-Level Barrier-Free Cooler	HAC8FSBL-Q ADA,	\$1,500–1,600	The manufacturer shall certify that the unit meets all NSF/ANSI 61 & 372 and Safe Drinking Water Act requirements

Recommended action:

Replace all plumbing components that contact water including angle stop and bubbler

Additional information:

[How to Identify Low-Lead Faucets and Fixture](#)

Funding for this project has been provided in full or in part through agreements with the State Water Resources Control Board and the California Department of Social Services. The contents of this document do not necessarily reflect the views and policies of the foregoing, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.